



Drinking Water Certificate

प्रमाणित किया जाता है कि विनायक. इन्टरनेशनल स्कूल, फतेहपुर, जिला सीकर (राज.) का स्वयं का पानी का ट्यूबवेल है एवं आर.ओ. प्लांट है तथा पर्याप्त पानी संग्रहण के लिए टैंक बना हुआ है इसमें शुद्ध व साफ पानी की व्यवस्था है, उक्त पानी की नमूना जाँच जन स्वास्थ्य अभियांत्रिकी विभाग की प्रयोगशाला सीकर से जाँच रिपोर्ट प्राप्त की गयी जो कि आवश्यक मापदण्ड के अनुसार है ।

संलग्न- Report of the comical examination of water.

(प्रियदर्शना)

सहायक अभियन्ता
जन स्वा. अभि. विभाग
नगर उपखण्ड II फतेहपुर

OFFICE OF THE SENIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, LABORATORY SIKAR
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No. Lab/Tech(Private Chem.Rep)/2026-2027/ **357**

Date - **08.07.2026**

To,

Principal
 Vinayak International School
 Fatehpur, Sikar (Rajasthan)

District: Sikar

Block : Urban

Reference :Your Letter No - 257 Date - 02.07.26

Sample Collected by- Sh. Ankit Bhojak

Date of Receipt : 03.07.2026

Date of Receipt : 03.07.2026

Source	Permissible value as per B.I.S. 10500/2012		RO
Source Location			
Gram Panchayat			School Campus Fatehpur
Village/Town/ City	Desirable limit	Permissible limit in absence of alternate Source	Fatehpur
Habitation			Fatehpur
Date of Collection			02.07.2026
Date of Examination			08.07.2026
Lab. Sample No.			R 373
Note :- All results Except pH are in mg/L			
pH	6.5-8.5	6.5-8.5	8.24
Turbidity (NTU)	1	5	0.96
Total Alkalinity (as CaCO ₃)	200	600	88
Total Hardness (as CaCO ₃)	200	600	48
Chloride (as Cl ⁻)	250	1000	28
Fluoride (as F ⁻)	1.0	1.5	0.326
Nitrate (as NO ₃ ⁻)	45	45	15
Sulphate (as SO ₄ ⁻²)	200	400	8
TDS	500	2000	151

Remarks:- Sample Not collected by Lab

Senior Chemist

PHED Lab Sikar

Dated:

No. Lab/Tech(Private Chem.Rep)/2026-2027/

Copy to:

1 The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.

Senior Chemist

PHED Lab Sikar